



GENERAL NOTES:

1. CONCRETE SHALL BE CLASS SI.
2. MINIMUM SIDEWALK THICKNESS SHALL BE FIVE INCHES (5").
3. SIDEWALK THICKNESS ACROSS DRIVEWAYS SHALL BE SIX INCHES (6") MINIMUM FOR RESIDENTIAL DRIVEWAYS, AND EIGHT INCHES (8") MINIMUM FOR NON-RESIDENTIAL DRIVEWAYS.
4. MAXIMUM LONGITUDINAL SLOPE SHALL NOT EXCEED 5% (20:1).
5. MAXIMUM TRANSVERSE SLOPE SHALL NOT EXCEED 2% (0.25"/FT).
6. A FOUR INCH (4") MINIMUM AGGREGATE SUB-BASE (CA-6 GRADATION) SHALL BE PROVIDED.
7. AGGREGATE SUB-BASE COURSE SHALL BE MECHANICALLY COMPACTED.
8. ALL SIDEWALK SHALL BE PROMPTLY BACKFILLED AND PROTECTED FROM DAMAGE.
9. REFER TO PAVEMENT DETAILS 3A, 3B (ADA SIDEWALK) AND 4 (SIDEWALK CONSTRUCTION).

REV.:	REV.:
REV.: TEG	REV.: 01-05-2024
DRAWN BY: VJGL	DATE: 02-16-1998

SIDEWALK

VILLAGE OF LOMBARD

PAVEMENT 2